


Client _____ Proiect _____
Nr. client _____ Nr. proiect _____
Persoana de contact _____ Poz. nr. _____
In grija _____ Locatia _____
Data _____

16.05.2011

Pag. 1 / 1



Date cerute

| | | |
|------------------------|-------|--------------------|
| Debit | 0 | l/s |
| Inaltime de pompare | 0 | m |
| Fluid | | |
| Temperatura fluid | 0 | K |
| Densitate | 998,3 | kg/m ³ |
| Viscozitate cinematica | 1,005 | mm ² /s |
| Presiune vaporizare | 0 | kPa |

Date generale pompa

| | |
|-------------------|-------------------|
| Fabricat | WILO |
| Tip | MVI 802/PN16 1~ |
| Tip pompa | Pompa cu un motor |
| Presiune nominala | PN 16 |
| Temp. min. fluid | 258 K |
| Temp. max. fluid | 393 K |

Date efectiv realizate

| | | |
|---------------------|------|-------|
| Debit | | l/s |
| Inaltime de pompare | | m |
| Turatie | 2900 | 1/min |
| Putere la arbore P2 | | kW |
| NPSH | | m |

Materiale/Etansare ax

| | |
|-------------------|-----------------------|
| Rotoare | Inox 1.4301 |
| Camere etaje | Inox 1.4301 |
| Carcasa presiune | Inox 1.4301 |
| Arbore | Inox 1.4301 |
| Capacul carcasei | Inox 1.4301 |
| Etansare | EPDM |
| Etansare mecanica | Wolfram carbid/grafit |

Dimensiuni

| | mm | | | | | |
|----|-----|--|--|--|--|--|
| E | 250 | | | | | |
| H | 574 | | | | | |
| h2 | 334 | | | | | |
| X | 143 | | | | | |
| M | 170 | | | | | |

| | |
|-----------|------------------|
| Aspiratie | Rp 1 1/2 / PN 16 |
| Refulare | Rp 1 1/2 / PN 16 |
| Greutate | 24,1 kg |

Date motor

| | | |
|-----------------------------------|----------------|-------|
| Putere nominala P2 | 0,75 | kW |
| Turatie nominala | 2950 | 1/min |
| Tensiune nominala | 1~230 V, 50 Hz | |
| Intensitate el. max.curent | 4,9 | A |
| Grad de protectie | IP 55 | |
| Toleranta permisa tensiune +/-10% | | |

Nr. art. in versiunea standard 4018790

